

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Follow-up Samples:

| Building Name | Date of Sample Events | Total Number Samples Collected | Initial First Draw Samples | | Follow-up Samples | |
|-------------------|-----------------------|--------------------------------|---|---------------------------------------|---|---------------------------------------|
| | | | | | First Draw Samples | |
| | | | Analyzed at or Below Action Level of 15 ppb | Analyzed Above Action Level of 15 ppb | Analyzed at or Below Action Level of 15 ppb | Analyzed Above Action Level of 15 ppb |
| Eggert Elementary | 10/8/2020 | 153 | 151 | 2 | N/A | N/A |
| | 4/9/2021 | 2 | N/A | N/A | 2 | 0 |
| Total: | | 155 | | | | |

** Follow-up samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Sample Results: Initial First Draw and Follow-up First Draw

| Sample # | Classroom or other Location | Fixture/Outlet type | Date Sampled | Laboratory Analysis in ppb |
|----------|-----------------------------|---------------------|--------------|----------------------------|
| 126.2-40 | Faculty Room M6 | Sink | 10/8/2020 | 21.5 |
| | | | 4/9/2021 | <1.00 - Cleared |
| 126.2-58 | Classroom C11 | Sink | 10/8/2020 | 52.4 |
| | | | 4/9/2021 | 5.22 - Cleared |