

## 1.2 Executive Summary of Sampling and Analysis:

### Total Number of Samples Collected by Building Classified by First Draw & Follow-up Samples:

Building Name	Date of Sample Events	Total Number Samples Collected	Initial First Draw Samples		Follow-up Samples	
					First Draw Samples	
			Analyzed at or Below Action Level of 15 ppb	Analyzed Above Action Level of 15 ppb	Analyzed at or Below Action Level of 15 ppb	Analyzed Above Action Level of 15 ppb
Windom Elementary	10/7/2020	120	118	2	N/A	N/A
	12/11/2020	2	N/A	N/A	2	0
Total:		122				

\*\* Follow-up samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

### Sample Results: Initial First Draw and Follow-up First Draw

Date	Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
10/7/2020	126.1-154	Room A-133	Sink	84.7
12/11/2021	126.1-154	Room A-133	Sink	5.46 - Cleared
10/7/2020	126.1-176	Kitchen – Pressure Cooker Faucet	Sink	118
12/11/2021	126.1-176	Kitchen – Pressure Cooker Faucet	Sink	2.41 - Cleared